



STROBE PLAN

- NOTES:
1. FOR GENERAL NOTES, LEGEND, TABLES, SEE DRAWING F-1-2-1.
 2. CONTRACTOR SHALL RUN ALL WIRING AND CONDUIT AND MAKE ALL CONNECTIONS FOR FLASH MOUNTED STROBE DEVICES MOUNTED ON WALLS SURFACES NECESSARY IN WALLS BEHIND WALLS.

STROBE CIRCUIT/LOADING TABLE									
STROBE TYPE AND MODEL	TYPE	1150d	300d	750d	1100d	CURRENT PER CIRCUIT (amps)	CIRCUIT LENGTH (ft)	QUANTITIES OF STROBES PER CIRCUIT	
STR-A	1	1	1	1	1	0.135	114	1	
STR-B	2	1	2	1	1	0.795	250	1	
STR-C	2	2	2	1	1	0.820	275	1	
STR-D	3	2	3	1	1	1.345	325	1	
STR-E	2	1	1	1	1	0.285	245	1	
STR-F	1	1	1	1	1	0.455	222	1	
GRAND TOTAL						3.865	1189		

THE PORT AUTHORITY
OF NY & NJ



Joseph R. Loring
& Associates, Inc.
consulting engineers

One Pennsylvania Plaza
New York, New York 10119-0045
Tel: (212) 563-7400
Fax: (212) 563-7382

SCR Design Organization, Inc.
architects
305 EAST 46 STREET
NEW YORK, N.Y. 10017
TEL: (212) 421-3500

1	6/24/98	AS BID	DC
No.	Date	Revision	Approved

Engineering Department
Design Division

The World Trade
Center

Title
TOWER 2
FLOOR 78
FIRE ALARM
STROBE
INSTALLATION AND
REMOVAL PLAN

This drawing subject to conditions in contract.
All inventions, ideas, designs and methods
herein are reserved to Port Authority and
may not be used without its written consent.

F.D.	F.D.	4565.000
Designed by	Drawn by	JRLA JOB No.
4/27/98	P.E.N.	3/32"=1'-0"
Date	Checked by	Scale
Contract Number	Drawing Number	
WTC-857.090	F-2-78-3	

